

(30) APG Media of Ohio, 9300 Johnson Rd, Athens, OH 45701
Proof of Ad 06/24/19

Notice to Bidders

Circleville City School District

Circleville City Schools is accepting qualified bids on the supply and installation of a 12,000 gallon horizontal, doublewall tank complete with 3/4 hp submersible pump, with ground level 3" fill capability with spill containment ground level 1-1/2" pump discharge plumbing, overfill prevention with alarm remote dispenser, hose, nozzle. Supply and install complete fuel management system and software.

Supply and install of a 2,000-gallon horizontal, doublewall tank complete with 3/4 hp submersible pump, with ground level 2" fill capability with spill containment, ground level 1-1/2" pump discharge plumbing, overfill prevention with alarm remote dispenser, hose, nozzle. Supply and install complete fuel management system and software.

Install 40' long x 26' wide x 4" thick concrete pad to accommodate 12,000 gallon and 2,000 gallon tanks. Two 3' x 12' x 3' thick footings shall be incorporated in pad to support 5,000 or 12,000 gallon tank. 4" bollards shall be placed around perimeter of pad no greater than 4' on center. Bollard height shall be no less than 36".

Obtain all necessary local and state installation permits.

Tank and installation must be in compliance with all applicable local regulations, Ohio Administrative Code, Ohio Fire Code, NFPA 30, NFPA 30A

Sealed Bids must be submitted in writing to Circleville City Schools, 388 Clark Drive, Circleville, Ohio, 43113 **by 3:00 p.m., August 15th, 2019**, and must include references and bond. Questions can be directed to Jonathan Davis, Superintendent, at (740) 474-4340.

The sealed bids will be opened at 11:00 a.m., August 16, 2019.

June 28, 2019 July 9, 2019
Circleville Herald - 552611