



www.ucasd.org

Union City Area School District

107 Concord Street
Union City, Pennsylvania 16438

(814) 438-3804
Fax: (814) 438-2030

Amy L. Coleman
Director of Curriculum/Special Programs
acoleman@ucasd.org

Matthew W. Bennett
Superintendent
mbennett@ucasd.org

Tara L. Lineman
Business Manager
tlineman@ucasd.org

Radon testing, Union City Area School District

Radon testing was performed on 4/2/2018 in both Elementary and Middle/High buildings, in each room that was occupied at any time of the day. Test results available upon request.

The reported results indicated that radon levels in the buildings tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends testing if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

Radon testing may be done every 5 years in both buildings.

Fact sheet:

www.epa.gov/radon/pubs/citguide.html